

Seismic Loss Assessment of Existing Hotel Building in Ecuador

Jose Poveda¹, Gerard J. O'Reilly²

1 – PhD Student, IUSS Pavia, Italy 2 – Associate Professor, IUSS Pavia, Italy









CENTRE FOR TRAINING AND RESEARCH ON REDUCTION OF SEISMIC RISK

Background

- Performance-based seismic assessment of existing buildings is inherently complex
- Many of these structures lack original design documents, especially in Ecuador
- These buildings are often seismically vulnerable as they typically predate modern seismic design standards
- Assessments must rely on building-specific data, field surveys, and advanced analysis techniques to mitigate uncertainties

Report: Trama, October 2020. Pictures by Rolf Blomberg and IGM (Instituto Geografico Militar)




Hotel Quito ingreso. Fotografía: Rolf Blomberg






Motivation

- Loss assessment is a handy tool in performance-based earthquake engineering
- It helps practitioners and building owners understand their building's performance much better
- FEMA P-58 and its implementation in PACT is a wellestablished approach
- Some issues arise:
 - Developed primarily for the US context it needs to be adapted for other regions of the world
 - Component-based requires a lot of input information that is not always available
- This study investigates these two issues via a case study application to a real hotel building in Quito, Ecuador



Seismic Loss assessment


General overview of PBEE Methodology, including storey loss functions





Case Study

- A seven-story central block hotel in Quito, Ecuador, built in the 1950s
- The structure includes perimeter columns, concrete core walls, and unidirectional slabs with embedded beams
- Assessment included soil properties, material strength, typical reinforcement details, and ambient noise vibrations
- Damageable inventory and repair costs are considered via surveys and Building Information Modelling (BIM)






Damageable inventory


	·	·				Ŭ				Τ.				_	_		_					Τ,		MU		tedies !	EDP				Tetal di	rpersian,	6	A.I.	ML	Arere	e Rese	ir Cart [\$1			CT/Di	irparrie	-		Die	tribetie	
COD.	DESCRIPTION	Suurce	Direc	EDP	Repair	Sek	Sub	PB .	- P2		p4		P6	P7 S	ı. s.	A PE	P1	p,		.	5 P4		ш				T	\neg	\top					-						\top	\top					DS DS	$\overline{}$	$\overline{}$
	DESCRIPTION .	-murca	itz	LUF	Unit	2	1	. .	' r	1"	~	"	~	" ·	: 1	1	"	"	r,	'' '	, "	1.	ll	DS1	DS2	DS3	DS4	DS	5 D:	S1 C	952	053	054	DSS	D51	DS2	DS3	DS4	d DSS	DS	1 D	52 D	953	DS4	DSS	1 2		, 5
B40-41 (32)	fan-conforming MF with inedequate development of reinforcing	MA P-50	-	-so ,	spornado	-	\rightarrow	24	29	29 21	22	23	22	-	+	-			-	-	-		# DS	0.015	0.00		+	-	-	0.4	0.4	\rightarrow	\rightarrow	$\overline{}$	32	0 199.3		+	+	0.744	H23 0.27	2004	\rightarrow	\rightarrow		Norm Norm	_	+
	aurriro reinfarced concrete walk with return flanger	1A P-58	1	-50	n.2	-	\rightarrow			5.7 105.3	135.7			135.7	-	20.2	2 20.2	1 10.71	20.22	10.21 11	22 20.2	8 80.28	- 2	0.0076			-	-	-	0.33	0.45	-	\rightarrow	$\overline{}$	9.7			-	-		N-42 0.		$\overline{}$	-		LogN Norm		+
02011.0216	fanalithic cart in place cancrete steirs with nascionic jaints Fl	1A P-50		SD .				2	2	1 1	1	- 1	- 1			-	-	1			-			0.0076						0.22	0.45					7 2006.7					1477 0.5					LogN LogNs		\neg
C3011.001a	Typrominfill well - 70790 mm.	1A P-51	0 P	SD .	m.Z					3 19.29						20.5				15.53 15			1	0.0021						0.6					4.2	7				0.15				=		LagNarm-a		\blacksquare
	iyyrum.infill.uell - 125mm FE	1A P-51	0 P		m.č	\vdash	\rightarrow			.91 11.97			27.92	\rightarrow	$\overline{}$	$\overline{}$	11.	1 11.11	11.23	\rightarrow	9.5	i4		0.0021		\vdash	$\overline{}$	$\overline{}$	$\overline{}$	0.6	\rightarrow	\rightarrow	\rightarrow	$\overline{}$	4.2		\vdash	$\overline{}$	_	0.15	424	$\overline{}$	\rightarrow	\rightarrow		LagNarma	\leftarrow	\perp
	Irick Infill wall - 91mm. C-	dans & Pro		SD /						02 1.6			_					1 10.7		15.251 3	.97		7 31	0.0015	0,004	4 0	.01		_	0.5	0.5	0.4	_		4.0	4.9	10] 37.	.52	_	_	_	_	_	_		Norm-ol	+	+
	Prick Infill well - 160 mm. C.	dans & Per dans & Per		SD /	- 3	-				36 316.3 36 10.36			7 72	54.31	-					31.59 44		4 02.12	1 3	0.0015	0,00	4 6	04		_	0.5	0.5	0.4		7/7	4.0	4 4.5	0 44	42		_			_	-		Normal Normal	+	+
	Ivick Infill well - 140mm. C- Ivick Infill well - 240mm. C-	dans & Per		50	m.c m.2	-				97 3.36			43	35.64	-	1.9				3.16		64.3		0.0015	0.00			-	-	0.5	0.5	0.4	$\overline{}$	_	4,0				-	-	-	-	-	-		Hermal Hermal	\vdash	+
	Haring	1010 07 01		SD /	m.2	-	\neg	2.76	23.	52 30.4	65.56	65.07	37	105	-	- "	170.5	5 121.9	124	122.6 07	.45 64.7	2 137.2	1	0.01		1			-	0.5	7.0		$\overline{}$		07.3		1	-		-	-	-	-	\pm		Normal	\vdash	+
	Dear - Single Outride Panel U	(R		-50	,			-1	7		12	12	3	5									1	0.01						0.4					31.0	#										Herm-el	\blacksquare	\Box
	Dear - Emorgon cy Exit U:	OR.		SD .		\Box													1	$\overline{}$	$\overline{}$	-	1	0.01			$\overline{}$	$\overline{}$	\perp					_							\perp	$\overline{}$	$\overline{}$	\rightarrow		Normal	$\overline{}$	\perp
	Dear-Interior U:	:R		SD .		-	_							4	11.0				+	-	_	-	1	0.01		-	_	-	-		_		100				1				-	_	-	\rightarrow		Horm-ol	\rightarrow	\rightarrow
	eilet U:	R		SD (•	- 1			11 12	ani	1111	Δ	2 2	4 T	MI1	TΩ	re	ent	+	-	-	-	1 1	0.01		-	-	-	+	- Н	– rs	וחג	liti	AC	· 2	m	7 r	An	aiı		+	-	\rightarrow	-		Normal .		+
	Sink U: Destric connection U:	10		SD .		- 1	_	U	uc	<i>A</i>	uu	C	, ,	<i>1</i>	uп			,,,,	+	-	-	-	1 1	0.01	-	_	-	-	-		1 C	ıyı	111		u	1111	<i>1</i>	CΡ	'all		-	-	-	-		Norm-ol	-	+
	IO Paragot U:	in .		FA[4]	2	1 1	_															_	2	1.2	1/		-	$\overline{}$	-												-	-	-	-	-	Normal .	\vdash	+
	Fater distribution a)/4	1A P-51	0 P	FA[4]		154,7	19		N //	\sim l \sim	. 4L	or.	\sim	بايم	20	4	44	20	J				2	1.5	2.6	6								00	0	to					637 0	4054				agNorm.al		
	fotor Geteilection #2-0" FI	1A P-50	0 P	FA[4]		154,7	1.1	- 16	; V 6	718	ון (ш	UU	ıuı	1U	ul	Lľ	ne	I				2	1.5	2.0	6								CC	JS	เร					637 0					LagHarmal		\Box
	fotor dirtribution #4-0" Ft	1A P-51		FA[4]	-	193,1	10		•					. J'	-				T				2	1.5	2,4	6			_							_					437 e				L,	LagNarm-a	\vdash	\bot
	Sanitary Warts Piping 199mm FI	1A P-50	0 P	FA[4]		12													+	-	-	-	- 3	1.2	2.4	4	+	-	-			_			B 22	4 611	,	_	_	-	750 0		\rightarrow	\rightarrow		Lagharmal	\vdash	+
	Sanitary Warto Piping 200 mm. Ft	1A P-58 1A P-58		FA[4]	*	27.05	34.8				h	VI I	ıΙત	In	\sim				+	-	-	+	- 3	1.2	2.4	1	-	-	-	0.4	0.4	_	\rightarrow	_	5.9	8 12.3	-	-	-	9.5	750 0	3401	\rightarrow	\rightarrow		LagHarm-s	\rightarrow	+
	Finitary Warts Piping #4-0" FI Piping Systems - Gas distribution U	'A		FA[q]		27.09	64					u	пu	in	Ч				+	-	-	_	1 1	0.55	- 2.4	1	+	-	-	0.4	9,4	-	\rightarrow	$\overline{}$	4.19			+	-		N-37 0		\rightarrow	-		LogNormal	\vdash	+
D1014,012		IA P-50	o P	FA[4]		17.72	44.							,					+	-		+	1 3	0.31		_	$\overline{}$			0.45	-	-	\rightarrow	$\overline{}$	51529.7	2				4.7	-21		-	-	-	$\neg \neg$	\vdash	+
	Fand Water Filter For paol U:	OR .	0 P	FA[4]			- 4												-				1	1.1						0.4					5145.0										\rightarrow	\rightarrow	\vdash	+
	fater pump for pool recirculation.	(R	0 P	FA[4]			2																1	1,1						0.4					646,00									\equiv	\equiv	\bot	\blacksquare	\Box
	feater 4.312 lbr/hr, with horner of 220 V / 3Ph / 60 Hz @ 5HP. U:	OR.										$\overline{}$			$\overline{}$	_	_	$\overline{}$	$\overline{}$	_	_	-	1	1.1			_	_	_	0.4	_		$\overline{}$		4019.5					_	$\overline{}$	_		\rightarrow	\rightarrow	$\overline{}$	$\overline{}$	\perp
	(ask5m)	R	_						4		\vdash	\rightarrow	\rightarrow	\rightarrow	-	-	-	\rightarrow	\rightarrow	\rightarrow	\rightarrow	-	1	1.1		-	-	-	-	0.4	\rightarrow	_	\rightarrow	_	641,7		-	-	-	-	-	\rightarrow	\rightarrow	\rightarrow	\rightarrow	\rightarrow	\rightarrow	+
	U: U	IR.	_		1)	iffe	⊃rı	⊃n	T		\longrightarrow	\rightarrow	\rightarrow	-	-	-	-	+	\rightarrow	-	-	-	1 1	1.1	-	-	-	-	+	0.4	-	-	\rightarrow	$\overline{}$	6130.0		+	-	-	+	-	-	-	-	\rightarrow	+	+	+
	fot water tank 50m3 U: Nazel Tank 1000 gale U:	in .	_				υ ι ι		· ·		-	\rightarrow	\rightarrow	-	-	-	-	-	\rightarrow	-	-	-	1 7	- 13	-	_	-	-	-	0.4	-	_	\rightarrow	_	3007		-	-	-	-	-	-	-	-	\rightarrow	\rightarrow	-	+
	Paul he sterenchen ge Pat, 150 km U	IR IR	_								-	\rightarrow	\rightarrow	-	-	+	-	+	\rightarrow	-	-	-	1 1	1.1	-	 	-	-	-	0.4	-	-	\rightarrow	$\overline{}$	621.0		+	-	-	+	-	-	$\overline{}$	\rightarrow	\rightarrow	+	\vdash	+
	SandFilter 0.2m2 US				10 K	~ r	· ^ ·	^	nt		$\overline{}$	$\overline{}$	$\overline{}$	-	$\overline{}$		+	$\overline{}$	$\overline{}$	-	$\overline{}$	-	1 1	1.1			$\overline{}$	$\overline{}$	$\overline{}$	0.4	-		\neg		2495.0		+	$\overline{}$	$\overline{}$	$\overline{}$	-	-	$\overline{}$	-	\rightarrow	\rightarrow	\vdash	+
	/acussiPump 2201/3P5/40Hz @ 3 HP U	10		(cor	HL	ונא	ПŒ	111														1	1.1						0.4					607.0											\Box	\blacksquare	\Box
	'acussi he eter exchange Pat. 20 km U:	R				٠.١-		•							\perp								1	1,1			$\overline{}$			0,4					474.0						\perp			=	=	\bot	\blacksquare	\perp
D2022.011e	fot water Piping Dirtribution Ft	1A P-51	_								\vdash	\rightarrow	\rightarrow	-	_	_	-	-	\rightarrow	-	_	-	2	0.55	1.	1	_	_	-	0.4	0.4	_	\rightarrow	_	4.19			_	_		N-37 0		\rightarrow	\rightarrow		LogHarmal		\rightarrow
	Apper Piping Distribution. FI	1A P-58	_			typ	Δ	C			\vdash	\rightarrow	\rightarrow	-	-	-	-	-	\rightarrow	-	-	-	- 3	0.55		1	-	-	-	0,4	0.4	\rightarrow	\rightarrow	_	4.19			-	-		637 0		\rightarrow	-		agNarm-a		+
	fat waterrature Piping F1	1A P-50	_			LYK		O			-	\rightarrow	\rightarrow	-	-	-	-	-	\rightarrow	-	-	-		0.55	1.	1	-	-	-	0.4	0.4	-	\rightarrow	$\overline{}$	417.		-	-	-	9,7	N-37 0	4054	-	-		LogNormal	\vdash	+
	Norel Tank 5000 qele U: Feckup Heeter U:	re.	_			<i>-</i>					\vdash	\rightarrow	\rightarrow	-	-	-	+	_	\rightarrow	-	-	-	1 1	1.1		_	-	-	-	0.4	-	-	\rightarrow		19.5		+	+	-	-	-	-	-	-	\rightarrow	\rightarrow	\vdash	+
	n-durtrial Drying machina U	is.	6 P	FA[4]		$\overline{}$		-1	\neg	$\overline{}$	\vdash	\neg	\rightarrow	-	-	-	-	-	\rightarrow	-	$\overline{}$	-	1 1	1.1		-	-	$\overline{}$	-	0.4	-	-	\neg	-	5127.40		-	-	-	-	-	-	-	-	\rightarrow	\rightarrow	\vdash	+
	ndurtrial Drying machine U:	IR.	0 P	FA[q]				-1																1.1						0.4					9127.00	2										\Box	\blacksquare	\Box
	ndurtrial Washing Machine U:	78.	0 P	FA[4]				1	\perp														1	1.1						0.4					5331.0	4							-	\equiv		\blacksquare	\Box	\blacksquare
	ndurtrial Warking Mackina U	R		FA[4]		\vdash	\rightarrow	- 1	-	+	\vdash	\rightarrow	\rightarrow	\rightarrow	+	+	-	\vdash	\rightarrow	-	+	-	1 1	1,1		-	+	_	+	0,4	\rightarrow	\rightarrow	\rightarrow	_	5331.0		-	+	+	+	-	\rightarrow	\rightarrow	\rightarrow	\rightarrow	\dashv	\vdash	+
	Damartic Warking Mackina U:	JRI	0 P	FA[4]	•	\vdash	\rightarrow	- 2	-	+	\vdash	\rightarrow	\rightarrow	-	+	-	+	$\overline{}$	\rightarrow	-	-	-	1 1	1.1		-	+	-	-	0.4	\rightarrow	-	\rightarrow	$\overline{}$	760.9		-	+	-	+	-	-	\rightarrow	\rightarrow	\rightarrow	\dashv	\vdash	+
	Pamertic Drying Machine Usper Piping Distribution FI	1A P-50	OIP OIP	FA[q]	-	 	\rightarrow	-1	-	+	\vdash	\rightarrow	\rightarrow	-	+	+	+	1	\rightarrow	-	+	+	1 1	0.55			+	_	+	0.4	0.4	\rightarrow	\rightarrow		20.9		+	+	+	- 0.7	N-37 0	4054	\rightarrow	-	\rightarrow	nallaur	+	+
	Rigiran Machine U	OR COL	N P	FA[4]		 	\rightarrow	-1	-	+	\vdash	\rightarrow	\rightarrow	-	+	-		1	\rightarrow	-	-	-	1 1	1.1	'	1	$\overline{}$	-	-	0.4	7.4	-	$\overline{}$	$\overline{}$	2539.43		_	$\overline{}$	-	- 4.1		1000	\rightarrow	\rightarrow	—	LogNormal	\vdash	+
	Fmall Iran Machine U:	OR .	0 P	FA[4]				-1															1	1.1						0.4					209.0										=	\bot		
D5011.011a	rontermotion chamber U:	OR .	0 P	FA[4]	,			-1															1	1.01						0.6					99.83	2								\equiv	\equiv	\perp		\Box
D3041.011a	WAC Galvenized Sheet Metal Ducting less then 6.59, ft in crass sectional are FI	1A P-51	0 P	FA[4]	kg	652.9	1421	60	60	60 60	60	60	92.06	0	\perp								2	1.5	2.21	ş			_	0.4	0.4	-			6,6								-	$\overline{}$	$\overline{}$	-	\vdash	\Box
	WACF4n70CFMF0,15inH20 FE	IA P-51	0 P	FA[4]	*	1 1	\rightarrow	_	_	_	\vdash	\rightarrow	\rightarrow	_	+	_	-	$\overline{}$	\rightarrow	_	_	_	2	1.9		-	+	_	_	0.4	\rightarrow	_	\rightarrow	_	203.2		-	_	_	_	-	_	_	\rightarrow	\rightarrow	\dashv	\vdash	\dashv
	#VAC F-ss 50 CFM F0,15 is H20 F1	IAP-58	0 P	FA[4]		$\overline{}$	-1	-	-	+	\vdash	\rightarrow	\rightarrow	-1	+	-	+	-	\rightarrow	-	-	-	1 3	1,9		+	+	-	-	0.4	\rightarrow	-	\rightarrow	$\overline{}$	142.2		+	+	-	+	-	-	\rightarrow	-	\rightarrow	\dashv	\vdash	+
	WAC Fan UPBLAST 2.500 CFM / 0,75 in M20 F1 Not ribution Panel F1	1A P-51	90	FA[q]		-	-	-	-	,	1	- 2	-	-3	-	-	+	_	\rightarrow	-	-	_	1 1	2.16		_	-	-	-	0.4	\rightarrow	-	\rightarrow	_	99.0		+	-	-	-	-	-	\rightarrow	-	\rightarrow	\rightarrow	\vdash	+
	ackers Ft	1A P-50/U		FA[4]		1 1	155.4	-1	1	1	1 1	-1	-7	7	+	-		1	\rightarrow	-	-		1 3	0.55		_	+	_	-	0.45	-	-	_		226.			_	_	-	-	-	-	-	\rightarrow	$\dashv \dashv$	\vdash	+
	Paragorasm. Ft	1A P-58/U		FA[4]				20.5	1.79 5.	÷5 5.÷5	5,15	5.84	6,96										1	0.55						0.45					31	0									=	\bot		
	quipment ream / Cafataria FI	1A P-50/U	0 P	FA[4]	m2		\$00.0	134.9					46.43										1	0.55						0.45					42	s									=	\perp		\Box
	Convention center ft	1A P-51/U	0 P	FA[4]	m.2		337.4																1	0.55						0.45					521											\perp		\perp
	Implayee canteen FE	1A P-51/U		FA[4]		\Box	61,60	_	_	_				_	_	_		\Box		_			1	0.55						0.45	_	_			200				_	_	_	_	_	$\overline{}$	$\overline{}$	\dashv	\vdash	\perp
	ndurtrial Kitchen Ft	1A P-58/U		FA[4]		\vdash	25	\rightarrow	-	+	\mapsto	212	\rightarrow	-	+	+	+	$\overline{}$	\rightarrow	-	-	+	1 1	0.55		-	+	-		0.45	\rightarrow	\rightarrow	\rightarrow	_	150		+	+	-	+	-	-	\rightarrow	\rightarrow	\rightarrow	\dashv	\vdash	+
	Restreem FI	1AP-50/U		FA[q]		$\overline{}$	48,9 217	101.0	-	+	\vdash	24.21	\rightarrow	-	+	-	+	1	\rightarrow	-	-	+	1 1	0.55		_	+	-		0.45	\rightarrow	-	\rightarrow	$\overline{}$	121	-	+	+	-	+	-	-	\rightarrow	-	\rightarrow	\dashv	\vdash	+
	Office / Mortingram F1 Starer / Frant dark F1	1A P-50/U		FA[4]		 	197,8	201.0	-	+	$\overline{}$	\rightarrow	\rightarrow	-	-	-	+	1	-	-	$\overline{}$	_	1 3	0.55		_	+	_		0.45	-	-	\rightarrow	$\overline{}$	521		+	_	-	-	-	-	\rightarrow	-	\rightarrow	\dashv	\vdash	+
	fetal reem Ft	1A P-50/U		FA[4]				200.0 4	96.9 49	.9 450	454												1 1	0.55						0.45					100	0								\neg	\rightarrow	\neg	\Box	\Box
	Restaurant	1A P-51/U		FA[q]	m.č							506.4											1	0.55						0.45					27	0										\Box		
_							_		_	_						•	-										_										_			_					$\overline{}$	$\overline{}$	_	_



Damageable inventory

- BIM aids in visualising and grouping components together and then estimating their respective quantities like mechanical and electrical equipment, piping, partition walls, contents, sanitary units, and façade elements
- A local expert compiled repair and replacement costs after conducting a detailed pricing analysis for the building's specific units and country context







Relative distribution of replacement value

- From the analysis, we could quickly identify:
 - Relative distribution of the value of the damageable components
 - Which group they belonged to (i.e., structural or non-structural)
 - Which types of demands they were sensitive to (e.g., drifts or accelerations)
- With this kind of information, the source of losses and relative distribution can be easily identified


PSD – Peak Storey Drift PFA – Peak Floor Acceleration






Storey loss functions

- Because the damageable inventory, fragility functions and repair cost functions are known, it is possible to simplify greatly
- Ramirez and Miranda (2009) proposed condensing these steps down to a few functions
- These are <u>storey loss functions</u> that link EDP directly to the expected economic loss
- Remove the need for a component-based analysis







Ramirez, C. M., & Miranda, E. (2009). Building Specific Loss Estimation Methods & Tools for Simplified Performance Based Earthquake Engineering. Blume Report No. 171.



Storey loss functions

- Development of Storey Loss Functions (SLFs) by Monte Carlo simulations for Peak Story Drift (PSD) and Peak Floor Acceleration (PFA) as the Engineering Demand Parameters (EDPs) due to their common usage and available fragilities for non-structural elements (NSEs)
- Generalized Storey Loss Functions (GSLFs) facilitate using SLFs for similar case studies in other studies beyond the current one. The obtained SLFs were normalized by the total repair cost for each story








Analysis


- Probabilistic seismic hazard analysis (PSHA) with average spectral acceleration (AvgSA) as the intensity measure (IM), seismic disaggregation for 10 return periods, and 30 ground motion records selected with conditional spectra
- Non-linear analysis includes PSD and PFA as EDP
- Derived fragilities for four damage states.
- Collapse was defined by 2.25% Storey drift


Demolition was defined by 1.5% Residual storey drift














Expected annual losses

- The vulnerability function of the expressed hotel in terms of the expected loss ratio, normalised to a total replacement cost of \$6.4 million and disaggregated for collapse, demolition, and structural and non-structural repair losses
- EAL computed to be 0.525%

Disaggregation of repair losses for each of the eight stories, categorised by EDP, and for four return





Summary

Seismic Loss Assessment is a valuable tool that helps practitioners and building owners understand their building's performance

- Building Information Modeling (BIM) aids in visualising and grouping components together, then estimating their respective quantities
- Locally compiled repair and replacement costs contribute to develop Seismic Loss Functions (SLFs)
 and Generalized Loss Functions (GLFs) for the ecuadorian context, extending their applicability
- Loss assessment facilitates the identification of the sources of losses and their relative distribution



Questions?









CENTRE FOR TRAINING AND RESEARCH ON REDUCTION OF SEISMIC RISK